

CALGREEN RESIDENTIAL CHECKLIST – MANDATORY ITEMS

COMMUNITY DEVELOPMENT DEPARTMENT • BUILDING DIVISION ALBERT SALVADOR, P.E., C.B.O., BUILDING OFFICIAL 10300 TORRE AVENUE • CUPERTINO, CA 95014-3255 (408) 777-3228 • FAX (408) 777-3333 • building@cupertino.org

PURPOSE:

The 2013 CalGreen Code applies to all newly constructed hotels, motels, lodging houses, dwellings, dormitories, condominiums, shelters, congregate residences, employee housing, factory-built housing and other types of swellings with sleeping accommodations and new accessory buildings associated with such uses. Existing site and landscaping improvements that are not otherwise disturbed are not subject to the requirements of CALGreen.

Project Name:	
Project Address:	
Project Description:	

Instructions:

- The Owner or the Owner's agent shall employ a licensed professional experienced with the California Green Building Standards Codes to verify and assure that all required work described herein is properly planned and implemented in the project.
- The licensed professional, in collaboration with the owner and the design professional shall initial Column
 2 of this checklist, sign and date Section 1 Design Verification at the end of this checklist and have the checklist printed on the approved plans for the project.
- Prior to final inspection by the Building Department, the licensed professional shall complete Column 3 and sign and date Section 2 - Implementation Verification at the end of this checklist and submit the completed form to the Building Inspector.

MANDATORY FEATURE OR MEASURE	Column 2 Project Requirements	Column 3 Verification
A4.1 PLANNING AND DESIGN		
Planning and Design - Site Development		
4.106.2 Storm water drainage and retention during construction. A plan is developed and implemented to manage storm water drainage during construction.		
4.106.3 Grading and paving. The site shall be planned and developed to keep surface water away from buildings. Construction plans shall indicate how site grading or a drainage system will manage all surface water flows.		

A4.2 ENERGY EFFICIENCY	
General	
4.201.1 Low-rise residential buildings shall meet or exceed the minimum standard design required by the California Energy Standards.	
A4.3 WATER EFFICIENCY AND CONSERVATION	
Indoor Water Use	
4.303.1 Water conserving plumbing fixtures and fittings. Plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) shall comply with the following:	
□ 4.303.1.3.2 Water Closets. The effective flush volume of all water closets shall not exceed 1.28 gallons per flush. Tank-type water closets shall be certified to the performance criteria of the U.S. EPA WaterSense Specifications for Tank-type Toilets.	
4.303.1.3.2 Urinals. The effective flush volume of urinals shall not exceed 0.5 gallons per flush.	
□ 4.303.1.3.1 Single Showerheads. Showerheads shall have a maximum flow rate of not more than 2.0 gallons per minute at 80 psi. Showerheads shall be certified to the performance criteria of the U.S. EPA WaterSense Specification for showerheads.	
□ 4.303.1.3.2 Multiple Showerheads serving one shower. When a shower is served by more than one showerhead, the combined flow rate of all showerheads and/or other shower outlets controlled by a single valve shall not exceed 2.0 gallons per minute at 80 psi, or the shower shall be designed to allow only one shower outlet to be in operation at a time.	
□ 4.303.1.4.1 Residential lavatory faucets. The maximum flow rate of residential lavatory faucets shall not exceed 1.5 gallons per minute at 60 psi. The minimum flow rate of residential lavatory faucets shall not be less than 0.8 gallons per minute at 20 psi.	
□ 4.303.1.3.2 Lavatory faucets in common and public use areas. The maximum flow rate of lavatory faucets installed in common and public use areas (outside of dwellings or sleeping units) in residential buildings shall not exceed 0.5 gallons per minute at 60 psi.	
□ 4.303.1.4.3 Metering faucets. Metering faucets when installed in residential buildings shall not deliver more than 0.25 gallons per cycle.	
■ 4.303.1.4.4 Kitchen Faucets. The maximum flow rate of kitchen faucets shall not exceed 1.8 gallons per minute at 60 psi. Kitchen faucets may temporarily increase the flow above the maximum rate, but not to exceed 2.2 gallons per minute at 60 psi, and must default to a maximum flow rate of 1.8 gallons per minute at 60 psi.	
4.303.2 Standards for plumbing fixtures and fittings. Plumbing fixtures and fittings shall be installed in accordance with the California Plumbing Code, and shall meet the applicable standards referenced in Table 1401.1 of the California Plumbing Code.	

Outdoor Water Use		
4.304.1 Irrigation controllers. Automatic irrigation systems installed at the time of final inspection shall be weather-based.		
4.304.1.1 Controllers shall be weather- or soil moisture-based controllers that automatically adjust irrigation in response to changes in plants' needs as weather conditions change.		
□ 4.304.1.2 Weather-based controllers without integral rain sensors or communication systems that account for local rainfall shall have a separate wired or wireless rain sensor which connects or communicated with the controller(s). Soil moisture-based controllers are not required to have rain sensor input.	stems that account for local rainfall shall have a separate ain sensor which connects or communicated with the	
A4.4 MATERIAL CONSERVATION AND RESOURCE E	FFICIENCY	
Enhanced Durability and Reduced Maintenance		
4.406.1 Rodent proofing. Annular spaces around pipes, electric cables, conduits, or other openings in plates at exterior walls shall be protected against the passage of rodents by closing such openings with cement mortar, concrete masonry or similar method acceptable to the enforcing agency.		
Construction Waste Reduction, Disposal and Recycling		
4.408.2 Construction waste management plan. Where a local jurisdiction does not have a construction and demolition waste management ordinance, a construction waste management plan shall be submitted for approval to the enforcing agency.		
Building Maintenance and Operation		
4.410.1 Operation and maintenance manual. At the time of final inspection, an operation and maintenance manual shall be provided to the building occupant or owner.		
A4.5 ENVIRONMENTAL QUALITY		
Fireplaces		
4.503.1 General. Install only a direct-vent sealed-combustion gas or sealed wood-burning fireplace, or a sealed woodstove.		
Pollutant Control		
4.504.1 Covering of duct openings and protection of mechanical equipment during construction. Duct openings and other related air distribution component openings shall be covered during construction.		
4.504.2.1 Adhesives, sealants and caulks. Adhesives, sealants and caulks shall be compliant with VOC and other toxic compound limits.		
4.504.2.2 Paints and coatings. Paints, stains and other coatings shall be compliant with VOC limits.		
4.504.2.3 Aerosol paints and coatings. Aerosol paints and other coatings shall be compliant with product weighted MIR Limits for ROC and other toxic compounds.		

4.504.2.4 Verification. Documentation shall be provided to verify that compliant VOC limit finish materials have been used.		
4.504.3 Carpet Systems. Carpet and carpet systems shall be compliant with VOC limits.		
4.504.4 Resilient flooring systems. Eighty (80) percent of floor area receiving resilient flooring shall comply with the VOC-emission limits defined in the Collaborative for High Performance Schools (CHPS) Low-emitting Materials List or be certified under the Resilient Floor Covering Institute (RCFI) FloorScore program.		
4.504.5 Composite wood products. Particleboard, medium density fiberboard (MDF), and hardwood plywood used in interior finish systems shall comply with low formaldehyde emission standards.		
Interior Moisture Control		
4.505.2 Concrete slab foundation. Required vapor retarders and capillary breaks are also required to comply with CalGreen Section 4.505.2.1.		
4.505.3 Moisture content of building materials. Moisture content of building materials used in wall and floor framing is checked before enclosure.		
Indoor Air Quality and Exhaust		
4.506.1 Bathroom exhaust fans. Exhaust fans which terminate outside the building are provided in every bathroom.		
Environmental Comfort		
 4.507.2. Duct systems are sized and designed and equipment is selected using the following methods: 1. Establish heat loss and heat gain values according to ACCA Manual J or equivalent. 2. Size duct systems according to ACCA 29-D (Manual D) or equivalent. 		
 Select heating and cooling equipment according to ACCA 36-S (Manual S) or equivalent. 		
INSTALLER AND SPECIAL INSPECTOR QUALIFICATION	ONS	
Qualifications		
702.1 Installer training. HVAC system installers are trained and certified in the proper installation of HVAC systems.		
702.2 Special inspection. The Licensed Professional responsible to verify CALGreen compliance is qualified and able to demonstrate competence in the discipline they inspect and verify.		
Verifications		
703.1 Documentation. Verification of compliance with CALGreen may include construction documents, plans, specifications, builder or installer certification, inspection reports, or other methods acceptable to the enforcing agency which show substantial conformance. Implementation verification shall be submitted to the Building Department after implementation of all required measures and prior to final inspection approval.		

Page 5 of 5

CALGREEN SIGNATURE DECLARATIONS

Project Name:

Project Address:

Project Description:

SECTION 1 – DESIGN VERIFICATION

Complete all lines of Section 1 - "Design Verification" and submit the completed checklist (Columns 1 and 2) with the plans and building permit application to the Building Department.

The owner and design professional responsible for compliance with CalGreen Standards have revised the plans and certify that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2013 California Green Building Standards Code as adopted by the City of Cupertino.

Owner's Signature	Date
Owner's Name (Please Print)	
Design Professional's Signature	Date
Design Professional's Name (Please Print)	
Signature of License Professional responsible for CalGreen compliance	Date
Name of License Professional responsible for CalGreen compliance (Please Print)	Phone
Email Address for License Professional responsible for CalGreen compliance	

SECTION 2 – IMPLEMENTATION VERIFICATION

Complete, sign and submit the competed checklist, including column 3, together with all original signatures on Section 2 to the Building Department prior to Building Department final inspection.

I have inspected the work and have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with this Green Building Checklist and in accordance with the requirements of the 2013 California Green Building Standards Code as adopted by the City of Cupertino.

Name of License Professional responsible for CalGreen compliance (Please Print)

Signature of License Professional responsible for CalGreen compliance

Email Address for License Professional responsible for CalGreen compliance

Date

Phone