

# Memo

**Date:** February 9, 2015

**To:** Ryan Shum  
Assistant Project Manager  
David J. Powers & Associates, Inc.

**From:** Michael Thill  
Principal Consultant  
Illingworth & Rodkin, Inc.

**Subject:** **Cupertino Civic Center Master Plan, Cupertino, CA –  
Construction Noise and Vibration Assessment**

---

This memo presents the results of the construction noise and vibration assessment completed for the Cupertino Civic Center Master Plan Project in Cupertino, California. The proposed project includes replacing the existing City Hall building with a new 40,000-square-foot City Hall building and expanding the existing library to include a new Program Room. The new City Hall building would be located on the northwest portion of the Civic Center site in the same general location of the existing City Hall building. The library would be expanded to the south onto an existing grass area. The existing Civic Center Community Hall building and turf field would remain unchanged. This memo provides an evaluation of noise and vibration levels resulting from project construction activities and recommends measures to reduce construction noise levels. Appendix A presents the fundamentals of environmental noise and vibration for those who may not be familiar with acoustical terminology and/or concepts.

## **Description of Construction Activities**

The project would be constructed over an approximate 15-month period, beginning in 2016. Grading and excavation will be limited to the location of the New City hall with its associated basement parking and, the excavation for the library expansion foundation. The grading and excavation activities would take approximately 30 days to complete if one excavator is used, and 15 days if two excavators are used. A total of approximately 630,900 cubic feet of soil (624,400 cubic feet for the new City Hall building and associated below-grade parking garage and 6,500 cubic feet for the library expansion) would be excavated to construct the proposed project. Construction equipment storage and staging would occur onsite.

## **Regulatory Criteria - Noise**

*City of Cupertino Municipal Code.* The City of Cupertino regulates noise within the community in Chapter 10.48 (Community Noise Control) of the Municipal Code. Noise from grading, construction, and demolition is limited as follows:

A. Grading, construction and demolition activities shall be allowed to exceed the noise limits of Section 10.48.040 during daytime hours (7:00 a.m. to 8:00 p.m. on weekdays, and 9:00 a.m. to 6:00 p.m. on weekends); provided, that the equipment utilized has high-quality noise muffler and abatement devices installed and in good condition, and the activity meets one of the following two criteria:

1. No individual device produces a noise level more than eighty-seven dBA at a distance of twenty-five feet (7.5 meters); or
2. The noise level on any nearby property does not exceed eighty dBA.

B. Notwithstanding Section 10.48.053A, it is a violation of this chapter to engage in any grading, street construction, demolition or underground utility work within seven hundred fifty feet of a residential area on Saturdays, Sundays and holidays, and during the nighttime period, except as provided in Section 10.48.030.

C. Construction, other than street construction, is prohibited on holidays, except as provided in Sections 10.48.029 and 10.48.030.

D. Construction, other than street construction, is prohibited during nighttime periods unless it meets the nighttime standards of Section 10.48.040.

E. The use of helicopters as a part of a construction and/or demolition activity shall be restricted to between the hours of nine a.m. and six thirty p.m. Monday through Friday only, and prohibited on the weekends and holidays. The notice shall be given at least twenty-four hours in advance of said usage. In cases of emergency, the twenty-four hour period may be waived. (Ord. 1871, (part), 2001)

### **Construction Noise Assessment**

Noise generated by project-related construction activities would be a function of the noise levels generated by individual pieces of construction equipment, the type and amount of equipment operating at any given time, the timing and duration of construction activities, the proximity of nearby sensitive land uses, and the presence or lack of shielding at these sensitive land uses. Construction noise levels would vary on a day-to-day basis during each phase of construction depending on the specific task being completed. Each construction phase would require a different combination of construction equipment necessary to complete the task and differing usage factors for such equipment. Construction noise would primarily result from the operation of heavy construction equipment and the arrival and departure of heavy-duty trucks.

FHWA's Roadway Construction Noise Model (RCNM) was used to calculate the maximum and average noise levels anticipated during each phase of construction. This construction noise model includes representative sound levels for the most common types of construction equipment and the approximate usage factors of such equipment that were developed based on an extensive database of information gathered during the construction of the Central Artery/Tunnel Project in Boston, Massachusetts (CA/T Project or "Big Dig"). The usage factors represent the percentage of time that the equipment would be operating at full power. Vehicles and equipment anticipated during each

phase of construction were input into RCNM to calculate source noise levels at a distance of 75 feet. Anticipated construction noise levels, by construction phase, are indicated in Table 1. Such noise levels would be expected at the nearest residential land uses located north of Rodrigues Avenue. Construction generated noise levels drop off at a rate of about 6 dBA per doubling of distance between the source and receptor. Therefore, construction noise levels would be expected to be approximately 10 dBA less at the nearest residential receptors located approximately 225 feet east of the site along Farallone Drive.

**TABLE 1      Calculated Construction Noise Levels at 75 feet**

Construction Phase (Exterior Construction)	Calculated Noise Level at a Distance of 75 feet from Construction	
	$L_{eq}$ , dBA	$L_{max}$ , dBA
Demolition	83	86
Site Preparation	79	80
Grading/Excavation	83	81
Trenching	77	80
Building - Exterior	84	80
Paving	79	76

Noise impacts resulting from construction depend on the noise generated by various pieces of construction equipment, the timing and duration of noise generating activities, and the distance between construction noise sources and noise sensitive receptors. Construction noise impacts primarily occur when construction activities occur during noise-sensitive times of the day (early morning, evening, or nighttime hours), the construction occurs in areas immediately adjoining noise sensitive land uses, or when construction durations last over extended periods of time. Typically, significant noise impacts do not result when standard construction noise control measures are enforced at the project site and when the duration of the noise generating construction period is limited to one construction season (typically one year) or less. A review of the construction schedule shows that all exterior construction activities would be completed within approximately 15 months. Once construction moves indoors, minimal noise would be generated at off-site locations.

Construction activities will be conducted in accordance with the provisions of the City of Cupertino Municipal Code. The Municipal Code allows construction and demolition activities during daytime hours; provided, that the equipment utilized has high-quality noise muffler and abatement devices installed and in good condition, and the activity meets one of the following two criteria:

1. No individual device produces a noise level more than eighty-seven dBA at a distance of twenty-five feet (7.5 meters); or
2. The noise level on any nearby property does not exceed eighty dBA.

Although noise generated by construction activities would be conducted in accordance with the provisions of the City of Cupertino Municipal Code, noise levels from some activities could exceed the quantitative noise limits contained in the Municipal Code and listed in Items 1 and 2, above. This would be a significant impact.

## Construction Noise Reduction Measures

Develop a construction noise mitigation plan, including, but not limited to, the following available controls:

- All equipment driven by internal combustion engines shall be equipped with mufflers, which are in good condition and appropriate for the equipment.
- The construction contractor shall utilize “quiet” models of air compressors and other stationary noise sources where technology exists.
- Unnecessary idling of internal combustion engines shall be prohibited.
- Construction staging areas shall be established at locations that will create the greatest distance between the construction-related noise sources and noise-sensitive receptors nearest the project site during all project construction.
- Locate stationary noise sources as far from sensitive receptors as feasible. If they must be located near receptors, adequate muffling (with enclosures where feasible and appropriate) will be used. Any enclosure openings or venting will face away from sensitive receptors.
- Locate material stockpiles as well as maintenance/equipment staging and parking areas as far as feasible from residential receptors.
- Neighbors located adjacent to the construction site shall be notified of the construction schedule in writing.
- Designate a project liaison that will be responsible for responding to noise complaints during the construction phase. The name and phone number of the liaison will be conspicuously posted at construction areas and on all advanced notifications. This person will take steps to resolve complaints, including periodic noise monitoring, if necessary. Results of noise monitoring will be presented at regular project meetings with the project contractor, and the liaison will coordinate with the contractor to modify any construction activities that generated excessive noise levels to the extent feasible.
- Require a reporting program that documents complaints received, actions taken to resolve problems, and effectiveness of these actions.
- Hold a preconstruction meeting with the job inspectors and the general contractor/on-site project manager to confirm that noise mitigation and practices (including construction hours, construction schedule, and noise coordinator) are completed.

The implementation of the reasonable and feasible controls outlined above would reduce construction noise levels emanating from the site by 5 to 10 dBA in order to minimize disruption and annoyance. With the implementation of these controls, as well as the Municipal Code limits on allowable

construction hours, and considering the relatively short duration of the noise generating construction period, the substantial temporary increase in ambient noise levels would be less-than-significant.

### **Regulatory Criteria - Vibration**

The California Department of Transportation recommends a vibration limit of 0.5 in/sec PPV for buildings that are structurally sound and designed to modern engineering standards, 0.3 in/sec PPV for buildings that are found to be structurally sound but where structural damage is a major concern, and a conservative limit of 0.08 in/sec PPV for ancient buildings or buildings that are documented to be structurally weakened. No ancient buildings or buildings that are documented to be structurally weakened are known to adjoin the project site. Therefore, groundborne vibration levels exceeding 0.3 in/sec PPV at the nearest receptors would have the potential to result in a significant vibration impact.

### **Construction Vibration Assessment**

The construction of the project may generate perceptible vibration in the immediate vicinity of the project site when heavy equipment or impact tools are used. Groundborne vibration levels would be highest during the demolition, site preparation, and grading/excavation phases when heavy equipment is used.

Table 2 presents typical vibration levels that could be expected from construction equipment at a distance of 25 feet. As indicated in Table 2, vibratory rollers and large bulldozers typically generate vibration levels ranging from 0.089 to 0.210 in/sec PPV at a distance of 25 feet. Vibration levels would vary depending on soil conditions, construction methods, and equipment used. Vibration impacts are generally confined to the immediate vicinity of the project site. Based on the data contained in Table 2, vibration levels would be less than 0.3 in/sec PPV at a distance of 25 feet.

The nearest structures to the project are located at least 75 feet from the nearest on-site construction activity. The potential for greatest vibration would be during heavy equipment movement, which would generate vibration levels of 0.210 and 0.170 in/sec PPV, respectively, at 25 feet from the source. These vibration levels at 75 feet would decrease to 0.027 and 0.063 in/sec PPV, respectively, at the nearest receiver, and would be well below the 0.3 in/sec PPV impact threshold for sound structures, and would also be below the 0.08 in/sec PPV applicable to structurally weakened structures. The majority of construction activity would occur well beyond these distances from the nearest receivers. Therefore, groundborne vibration from project construction would have no impact on existing structures in the project vicinity.

People can also be adversely affected by excessive vibration levels. The level at which humans begin to perceive vibration is 0.015 inches per second. Vibrations at 0.2 inches per second are considered bothersome to most people, while continuous exposure to long-term PPV is considered unacceptable at 0.12 inches per second. At a distance of 75 feet, the greatest vibration from the nearest construction activity would decrease to 0.027 and 0.063 in/sec PPV. Although vibration may at times be perceptible and/or annoying to occupants of nearby buildings, this would not be considered a significant impact due to the short duration and relative infrequency

of events. Therefore, project construction activities would not expose persons to excessive vibration levels.

**TABLE 2      Vibration Source Levels for Construction Equipment**

<b>Equipment</b>	<b>PPV at 25 ft. (in/sec)</b>	
Clam shovel drop	0.202	
Hydromill (slurry wall)	in soil	0.008
	in rock	0.017
Vibratory Roller	0.210	
Hoe Ram	0.089	
Large bulldozer	0.089	
Caisson drilling	0.089	
Loaded trucks	0.076	
Jackhammer	0.035	
Small bulldozer	0.003	

Source: Transit Noise and Vibration Impact Assessment, United States Department of Transportation, Federal Transit Agency, Office of Planning and Environment, May 2006.

## APPENDIX A: FUNDAMENTALS OF NOISE AND VIBRATION

### Fundamentals of Environmental Noise

Noise may be defined as unwanted sound. Noise is usually objectionable because it is disturbing or annoying. The objectionable nature of sound could be caused by its *pitch* or its loudness. *Pitch* is the height or depth of a tone or sound, depending on the relative rapidity (frequency) of the vibrations by which it is produced. Higher pitched signals sound louder to humans than sounds with a lower pitch. *Loudness* is intensity of sound waves combined with the reception characteristics of the ear. Intensity may be compared with the height of an ocean wave in that it is a measure of the amplitude of the sound wave.

In addition to the concepts of pitch and loudness, there are several noise measurement scales which are used to describe noise in a particular location. A decibel (dB) is a unit of measurement which indicates the relative amplitude of a sound. The zero on the decibel scale is based on the lowest sound level that the healthy, unimpaired human ear can detect. Sound levels in decibels are calculated on a logarithmic basis. An increase of 10 decibels represents a ten-fold increase in acoustic energy, while 20 decibels is 100 times more intense, 30 decibels is 1,000 times more intense, etc. There is a relationship between the subjective noisiness or loudness of a sound and its intensity. Each 10 decibel increase in sound level is perceived as approximately a doubling of loudness over a fairly wide range of intensities. Technical terms are defined in Table A-1.

There are several methods of characterizing sound. The most common in California is the A-weighted sound level or dBA. This scale gives greater weight to the frequencies of sound to which the human ear is most sensitive. Representative outdoor and indoor noise levels in units of dBA are shown in Table A-2. Because sound levels can vary markedly over a short period of time, a method for describing either the average character of the sound or the statistical behavior of the variations must be utilized. Most commonly, environmental sounds are described in terms of an average level that has the same acoustical energy as the summation of all the time-varying events. This energy-equivalent sound/noise descriptor is called  $L_{eq}$ . The most common averaging period is hourly, but  $L_{eq}$  can describe any series of noise events of arbitrary duration.

The scientific instrument used to measure noise is the sound level meter. Sound level meters can accurately measure environmental noise levels to within about plus or minus 1 dBA. Various computer models are used to predict environmental noise levels from sources, such as roadways and airports. The accuracy of the predicted models depends upon the distance the receptor is from the noise source. Close to the noise source, the models are accurate to within about plus or minus 1 to 2 dBA.

### Fundamentals of Groundborne Vibration

Ground vibration consists of rapidly fluctuating motions or waves with an average motion of zero. Several different methods are typically used to quantify vibration amplitude. One method is the Peak Particle Velocity (PPV). The PPV is defined as the maximum instantaneous positive or negative peak of the vibration wave. In this report, a PPV descriptor with units of mm/sec or in/sec is used to evaluate construction generated vibration for building damage and human complaints. Table A-3 displays the reactions of people and the effects on buildings that continuous vibration levels produce.

The annoyance levels shown in Table A-3 should be interpreted with care since vibration may be found to be annoying at much lower levels than those shown, depending on the level of activity or the sensitivity of the individual. To sensitive individuals, vibrations approaching the threshold of perception can be annoying. Low-level vibrations frequently cause irritating secondary vibration, such as a slight rattling of windows, doors or stacked dishes. The rattling sound can give rise to exaggerated vibration complaints, even though there is very little risk of actual structural damage.

Construction activities can cause vibration that varies in intensity depending on several factors. The use of pile driving and vibratory compaction equipment typically generates the highest construction related ground-borne vibration levels. Because of the impulsive nature of such activities, the use of the PPV descriptor has been routinely used to measure and assess ground-borne vibration and almost exclusively to assess the potential of vibration to induce structural damage and the degree of annoyance for humans.

The two primary concerns with construction-induced vibration, the potential to damage a structure and the potential to interfere with the enjoyment of life are evaluated against different vibration limits. Studies have shown that the threshold of perception for average persons is in the range of 0.008 to 0.012 in/sec PPV. Human perception to vibration varies with the individual and is a function of physical setting and the type of vibration. Persons exposed to elevated ambient vibration levels, such as people in an urban environment, may tolerate a higher vibration level.

Structural damage can be classified as cosmetic only, such as minor cracking of building elements, or may threaten the integrity of the building. Safe vibration limits that can be applied to assess the potential for damaging a structure vary by researcher and there is no general consensus as to what amount of vibration may pose a threat for structural damage to the building. Construction-induced vibration that can be detrimental to the building is very rare and has only been observed in instances where the structure is at a high state of disrepair and the construction activity occurs immediately adjacent to the structure.



**TABLE A-1 Definition of Acoustical Terms Used in this Report**

<b>Term</b>	<b>Definition</b>
Decibel, dB	A unit describing, the amplitude of sound, equal to 20 times the logarithm to the base 10 of the ratio of the pressure of the sound measured to the reference pressure. The reference pressure for air is 20.
Sound Pressure Level	Sound pressure is the sound force per unit area, usually expressed in micro Pascals (or 20 micro Newtons per square meter), where 1 Pascal is the pressure resulting from a force of 1 Newton exerted over an area of 1 square meter. The sound pressure level is expressed in decibels as 20 times the logarithm to the base 10 of the ratio between the pressures exerted by the sound to a reference sound pressure (e. g. , 20 micro Pascals). Sound pressure level is the quantity that is directly measured by a sound level meter.
Frequency, Hz	The number of complete pressure fluctuations per second above and below atmospheric pressure. Normal human hearing is between 20 Hz and 20,000 Hz. Infrasonic sound are below 20 Hz and Ultrasonic sounds are above 20,000 Hz.
A-Weighted Sound Level, dBA	The sound pressure level in decibels as measured on a sound level meter using the A-weighting filter network. The A-weighting filter de-emphasizes the very low and very high frequency components of the sound in a manner similar to the frequency response of the human ear and correlates well with subjective reactions to noise.
Equivalent Noise Level, $L_{eq}$	The average A-weighted noise level during the measurement period.
$L_{max}$ , $L_{min}$	The maximum and minimum A-weighted noise level during the measurement period.
$L_{01}$ , $L_{10}$ , $L_{50}$ , $L_{90}$	The A-weighted noise levels that are exceeded 1%, 10%, 50%, and 90% of the time during the measurement period.
Day/Night Noise Level, $L_{dn}$ or DNL	The average A-weighted noise level during a 24-hour day, obtained after addition of 10 decibels to levels measured in the night between 10:00 pm and 7:00 am.
Community Noise Equivalent Level, CNEL	The average A-weighted noise level during a 24-hour day, obtained after addition of 5 decibels in the evening from 7:00 pm to 10:00 pm and after addition of 10 decibels to sound levels measured in the night between 10:00 pm and 7:00 am.
Ambient Noise Level	The composite of noise from all sources near and far. The normal or existing level of environmental noise at a given location.
Intrusive	That noise which intrudes over and above the existing ambient noise at a given location. The relative intrusiveness of a sound depends upon its amplitude, duration, frequency, and time of occurrence and tonal or informational content as well as the prevailing ambient noise level.

Source: Handbook of Acoustical Measurements and Noise Control, Harris, 1998.

**TABLE A-2 Typical Noise Levels in the Environment**

Common Outdoor Activities	Noise Level (dBA)	Common Indoor Activities
	<b>110 dBA</b>	Rock band
Jet fly-over at 1,000 feet		
	<b>100 dBA</b>	
Gas lawn mower at 3 feet		
	<b>90 dBA</b>	
Diesel truck at 50 feet at 50 mph		Food blender at 3 feet
	<b>80 dBA</b>	Garbage disposal at 3 feet
Noisy urban area, daytime		
Gas lawn mower, 100 feet	<b>70 dBA</b>	Vacuum cleaner at 10 feet
Commercial area		Normal speech at 3 feet
Heavy traffic at 300 feet	<b>60 dBA</b>	
		Large business office
Quiet urban daytime	<b>50 dBA</b>	Dishwasher in next room
Quiet urban nighttime	40 dBA	Theater, large conference room
Quiet suburban nighttime	30 dBA	
Quiet rural nighttime	20 dBA	Library
		Bedroom at night, concert hall (background)
	10 dBA	
	0 dBA	Broadcast/recording studio

Source: Technical Noise Supplement (TeNS), Caltrans, November 2009.

**TABLE A-3 Reaction of People and Damage to Buildings From Continuous or Frequent Intermittent Vibration Levels**

<b>Velocity Level, PPV (in/sec)</b>	<b>Human Reaction</b>	<b>Effect on Buildings</b>
0.01	Barely perceptible	No effect
0.04	Distinctly perceptible	Vibration unlikely to cause damage of any type to any structure
0.08	Distinctly perceptible to strongly perceptible	Recommended upper level of the vibration to which ruins and ancient monuments should be subjected
0.1	Strongly perceptible	Virtually no risk of damage to normal buildings
0.3	Strongly perceptible to severe	Threshold at which there is a risk of damage to older residential dwellings such as plastered walls or ceilings
0.5	Severe - Vibrations considered unpleasant	Threshold at which there is a risk of damage to newer residential structures

Source: Transportation- and Construction-Induced Vibration Guidance Manual, California Department of Transportation, June 2004.