

November 19, 2019

Nandy Kumar
Sand Hill Properties
965 Page Mill Road
Palo Alto, CA 94304

**Re: Wolfe Road Pedestrian Walkway
Additional Review
Vallco Redevelopment
Cupertino, California**

Dear Nandy,

DCI Engineers (DCI) has conducted additional review of the existing pedestrian walkway spanning over Wolfe Road. Our investigation validates our earlier studies which determined that the walkway was designed as a stand-alone element. Removal of the adjacent west side mall structures did not adversely impact the walkway's stability. Similarly, removal of the adjacent east side mall structures will not adversely impact the walkway's stability.

If there are any further questions or concerns related to this matter, please feel free to contact us.

Sincerely,
DCI Engineers



Jeff D. Brink, P.E., S.E., LEED AP
Principal

